



TEAM SIGNATURE SOLUTIONS LLP

NABL Accredited Laboratory (Certificate No. TC-15090)

Approved by Pollution Control Board (Approval No. PCB/LAB/C21/2018)

2nd Floor, Eva Tower, Mannarkad Road, Perinthalmanna, Malappuram Dt, Kerala

Mob: +91 9061192481 - signaturepmna@gmail.com - www.signaturesolutions.in

TSS/QSP/7.8/QF-1

TEST REPORT

Report No.:250545B/2025

Date:31/05/2025

Name & Address of the Customer	Name of Sample:	*Ground Water(Bore Well)
* AL ANSAR ENGLISH MEDIUM PUBLIC SCHOOL & AL ANSAR UP SCHOOL MUNDAMPARAMBA	Sampling Done by:	Customer
	Lab No. of Sample:	250545
	Date of Receipt:	26/05/2025
	Date of Analysis:	26/05/2025 to 30/05/2025

RESULT OF ANALYSIS

SL.No	Characteristics	Method of Analysis	Result	Unit	Acceptable limit as per IS 10500:2012
1.	Color	VISUAL	Colorless		
2.	Odor	IS 3025(Part 5):2018	Agreeable		Agreeable
3.	Electrical Conductivity	IS 3025(Part 14):2013	42	μS/cm	-

BACTERIOLOGICAL ANALYSIS

SL.No	Characteristics	Method of Analysis	Unit	Result	Desirable limit as per IS 10500:2012
1.	Coliforms	IS 5401(Part 2),2012	MPN/100ml	Absent	Shall not be detected in/100ml
2.	E.coli	IS 5887(Part 1), 1976	MPN/100ml	Absent	Shall not be detected in/100ml

*Information provided by the customer

Disclaimer

- 1.Results relate only to the item tested
- 2.Report shall not be reproduced except in full without approval of the laboratory
- 3.Result apply to the sample as received

Opinion of Analyst: Satisfactory.

Prepared by:
Anasiya T

Verified by:
Sajesh T



Sajesh T
Authorised Signatory
Team Signature Solutions LLPP
Perinthalmanna


End of the Report

HEALTH AND SANITATION CERTIFICATE

Certified that I have visited the Al Ansar English Medium Public School, Ansar Nagar, Mundamparamba, Malappuram (KP/ IV – 263), run under the management of Al Ansar muslim welfare board, Ansar Nagar, Mundamparamba on 4/06/2005 and was found that the arrangement by the management and school authorities in the school and its premises for sanitation and health are satisfactory and the site where the school building and compound are situated is hygienic and has not any factors that may adversely affect the health of the children.

Place : Kuzhimanna

Date : 9/06/2005


for Health Inspector
Family Health Centre
Kuzhimanna - 673641